

**SCOPE OF WORK  
REMOVE/REPLACE  
EMERGENCY GENERATOR/MAIN BREAKER PANEL  
FDOT ORLANDO OFFICE COMPLEX  
133 S. SEMORAN BLVD.  
ORLANDO, FL.  
PROJECT NO. 418076-8-52-01  
CONTRACT NUMBER E-5L19  
ORANGE COUNTY**

**1.0 PURPOSE:**

The Florida Department of Transportation, District Five, requires the services of a Licensed Electrical Contractor to Remove and Replace the existing Emergency Generator and the Main Electrical Breaker Panel at their Orlando Office Complex located at 133 S. Semoran Blvd., Orlando, Fl.

**2.0 BID SUBMITTAL:**

1. Bids shall be submitted in accordance with supplied Electrical Engineer Plans and Specifications and should adhere to requirements of the Departments Bid Request Documents, Fixed Capital Outlay Non-Technical Specifications and this Scope.
2. This is a Furnish/Install project. Contractors shall include all aspects of this project as part of the bid which include, but not limited to: Tools, Labor, Materials, cost for permits/fees, including review of the State Fire Marshal if necessary, delivery/shipping and off loading.
3. **Generator Package and ATS's:** Contractors shall include in the bid, a Specifications list (quote without price) from the Generator Manufacture, for the Generator Package and Automatic Transfer Switches. This list should provide sufficient information to show compliance with Engineer Plans/Specifications. Shop drawings and detailed specifications shall be requested upon award.

**3.0 WORK HOURS:**

1. The majority of work shall be accomplished during the Departments standard work hours, 7:00am – 5:00pm Monday through Friday. The period of time needed to switch over power shall be accomplished over the weekend between the hours of 7:00pm Friday – 4:00am Monday.

Exhibit "A"

**4.0 CONTRACT TIME:**

1. Reference section A-21, page 11, FCO Non-Technical Specifications Package.

**5.0 ADMINISTRATION:**

1. Unless otherwise noted in writing, all administrative issues for this project shall be governed by the Fixed Capital Outlay Non-Technical Specifications Package attached herein.